

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1288:163 Page 1 of 1

CATEGORY: Power Units

LISTEE: Gamewell Company, 60 Pleasant Street, Ashland, MA 01721-1171
Contact: Brian Reynolds (203) 484-1200 FAX (203) 484-7309

DESIGN: Model CDP8 Constant Duty Power Supply. Comprised of the 31082 Motherboard, 31108 Enclosure, and 31057 Power supply. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120/240 VAC primary, 24 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

The system must have the secondary power supply capable of operating the system for at least 24 hours battery standby in the normal condition and followed by not less than 5 minutes of alarm as required per NFPA 72, 1999 Edition.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a power supply unit for use with separately listed compatible fire alarm control units and indicating devices. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instructions Manual for details

02-17-04KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager